



This report is not valid if the serial number has been defaced or altered

512927

DPN18

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 1: DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR

Registration No: 61502900 Branch No:
Trading Title: WOODVIEW LTD
Address: 24 LAUG ROAD BISHOPSTORRE YORK
Postcode: YO231QR Tel No: 01717511053

DETAILS OF THE CLIENT

Contractor Reference Number (CRN):
Name: DOC MOORE LTD
Address: 132 LAWRENCE STREET YORK
Postcode: YO10 3EB Tel No: 01916 351928

DETAILS OF THE INSTALLATION

Occupier:
Address: 46 WILKINSON ROAD YORK
Postcode: YO31 8HT Tel No:

PART 2: PURPOSE OF THE REPORT

Purpose for which this report is required:

REWED HOUSE (HMO)

Date(s) when inspection and testing was carried out: 25/03/2022

Records available: (No)

Previous inspection report available: (No)

Previous report date: (N/A)

PART 3: SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):

EARTHING AND BONDING ARE IN AN ACCEPTABLE CONDITION. P.V.C TRIP AND FORTH CABLE IS IN AN ACCEPTABLE CONDITION ACCESSORIES AND EQUIPMENT ARE IN AN ACCEPTABLE CONDITION SHOWING MINIMAL WEAR AND TEAR

Estimated age of electrical installation: (5) years

Evidence of additions or alterations: (No)

Overall assessment of the installation is: Satisfactory/Unsatisfactory* (delete as appropriate)

PART 4: DECLARATION

INSPECTION AND TESTING

I, being the person responsible for the inspection and testing of the electrical installation, particulars of which are described in PART 7, having exercised reasonable skill and care when carrying out the inspection and testing of the existing installation, hereby CERTIFY that the information in this report, including the observations (page 2) and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing.

Name (capital): TOM WOOD

Signature:

Date: 25/03/2022

REVIEWED BY QUALIFIED SUPERVISOR

Name (capital): TOM WOOD

Signature:

Date: 25/03/2022

*An unsatisfactory assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified in PART 6, or that further investigation (CODE F1) without delay is required.



PART 5: NEXT INSPECTION

I/we (as indicated on page 1) recommend that subject to the necessary remedial work being taken, this installation should be further inspected and tested after an interval of not more than 5 years/months (delete as appropriate)

Give reason for recommendation: REWired HOUSE

PART 6: OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN

CODES:	One of the following Codes, as appropriate, has been allocated to each of the observations made below to indicate to the person(s) responsible for the electrical installation the degree of urgency for remedial action	Risk of Injury	Immediate remedial action required	CODE C1 'Danger Present'	CODE C2 'Potentially Dangerous'	URGENT remedial action required	Improvement Recommended	CODE C3	Further Investigation Required	CODE F1
--------	--	----------------	------------------------------------	--------------------------	---------------------------------	---------------------------------	-------------------------	---------	--------------------------------	---------

Referring to the Schedule of Items Inspected (see PART 10), the attached Schedule of Circuit Details and Test Results (see PART 12), and subject to any agreed limitations listed in PART 7:

There are no items adversely affecting electrical safety (), OR The following observations and recommendations for action are made:

Item No	Observation(s)	Code	Location Reference
1	Consumer unit HAS NO fire RATING AND IS LOCATED ON FRT	(C3)	()
2	Consumer unit Receives fire material TO TOP	(C3)	()
3	GROUND FLOOR SHOWING ROOM FAN IS NOT WORKING	(C3)	()
4	NO TAG ON MAIN CABLE	()	()
5	3X LIGHTS ? OR OLD LIGHTS NOT IN USE ? IN KITCHEN ABOVE TV SEALED IN I HAVE	(F1)	()
6	NO PAVED TAPED OUT AS THIS WILL CAUSE DAMAGE TO CABLES	()	()
7	SMALL DETECTOR OUTSIDE SHOWING IS NOT WORKING OR CONNECTED (THERE IS A SEPARATE ALARM)	(NOT)	()
8	NO STICKERING TO CONSUMER UNIT	(C3)	()
9	1st FLOOR WALK SOCKET HAS CABLE TO FRONT RIGHT SIDE	(C3)	()
10	1st FLOOR BATHROOM FAN NOT WORKING	(C3)	()
11	2x LIGHTS OVER BATH FIRST FLOOR CORRIDOR AND NOT WORKING	(C3)	()
	2x LIGHTS OVER BATH FIRST FLOOR CORRIDOR AND NOT WORKING	(C3)	()
	2x LIGHTS OVER SHOWERS	(C3)	()
	ALL FAN'S CHANGED AND NOW WORKING		
	FIRE MATIL USED ON CONSUMER UNIT		

Additional pages? () State page numbers: ()
 Immediate action required for items: () State page numbers: ()
 Urgent remedial action required for items: () State page numbers: ()
 Improvement recommended for items: (1,2,3,7,9,10,11)
 Further investigation required for items: (5)

*The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.
 This report is based on the model forms shown in Appendix 6 of BS 7671
 Published by Certsure LLP Certsure LLP operates the NICEIC & ELECSA brands @ Copyright Certsure LLP (February 2019)
 Warwick House, Houghton Hall Park, Houghton Regis, Dunstable, LU5 5ZK

This report is not valid if the serial number has been defaced or altered
 512927 DPN18
DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT
 Small installations up to 100 A single phase supply
 Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations
 Original (to the person ordering the work)



PART 7 : DETAILS AND LIMITATIONS ON THE INSPECTION AND TESTING

The inspection and testing has been carried out in accordance with BS 7671:2018, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the Client and the Inspector prior to inspection.

Details of the installation covered by this report: FULL ELECTRICAL INSTALLATION TO HOUSE IN P.V.C TRIM AND EARTH CABLE (see additional page No.)

Agreed limitations including the reasons, if any, on the inspection and testing: CABLES NOT INSPECTED VISUALLY UNDER FLOORS AND IN WALLS (see additional page No.)

Extent of sampling (inspection only): 100% VISUAL INSPECTION ALL CIRCUITS TESTED 25% ACCESSORIES REMOVED AND INSPECTED (see additional page No.)

Operational limitations including the reasons: NONE (see additional page No.)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671:2018 - Requirements for Electrical Installations

This report is not valid if the serial number has been defaced or altered

512927 DPN18

PART 8 : SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type and earthing arrangements	Number and type of live conductors	Nature of supply parameters
TN-C-S: (<input checked="" type="checkbox"/>) TN-S: (.....) TT: (.....)	AC 1-phase, 2-wire: (<input checked="" type="checkbox"/>)	Nominal line voltage to Earth, U_0 : (240 V) Nominal frequency, f : (50.1 Hz) Prospective fault current, I_p (1)†: (206 kA) External loop impedance, Z_0 (1)†: (0.11 Ω)
Other (state):	Other (state):	(1) By enquiry, measurement, or by calculation
Supply protective device (BS IEN) (136)	Confirmation of supply polarity: (N/A)	
Type: (2)	Rated current: (100) A	
	Other sources of supply (as detailed on attached schedule)	Page No: (.....)

PART 9 : PARTICULARS OF INSTALLATION REFERRED TO IN THIS REPORT

Means of Earthing	Main protective conductors	Main protective bonding connections	Main switch / Switch-fuse / Circuit-breaker / RCD
Distributor's facility: (<input checked="" type="checkbox"/>)	Earthing conductor: (material) <u>COPPER</u> csa (16) mm ²	Water installation pipes: (<input checked="" type="checkbox"/>)	Type: (BS IEN) <u>COUPLER-F-3</u>
Installation earth electrode: (N/A)	Connection / continuity verified: (<input checked="" type="checkbox"/>)	Gas installation pipes: (N/A)	Location: (<u>CONSUMER UNIT</u>)
Where an earth electrode is used insert Type - rod(s), tape, etc: (N/A)	Main protective bonding conductors: (material) <u>COPPER</u> csa (10) mm ²	Oil installation pipes: (N/A)	No. of poles: (2)
Location: (.....)	Connection / continuity verified: (<input checked="" type="checkbox"/>)	Lightning protection: (N/A)	Current rating: (100) A
Electrode resistance to Earth: (.....) Ω		Other (state):	Where an RCD is used as the main switch RCD rated residual operating current, $I_{\Delta n}$: (N/A) mA
			Measured operating time: (.....) ms
			Rated time delay: (N/A) ms

*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current, I_p , and external earth fault loop impedance, Z_0 , must be recorded.

All fields must be completed. Enter either, as appropriate: ✓ if Acceptable condition; N/A if Not applicable; LIM if a Limitation exists; or Code appropriately - CODE 'C1', 'C2', 'C3' or 'F' (codes to be recorded in PART 6, with additional comments (where appropriate) on attached numbered sheets)



PART 10 - SCHEDULE OF ITEMS INSPECTED

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT
Small installations up to 100 A single phase supply

This report is not valid if the serial number has been defaced or altered

512927

DPN18

Issued in accordance with BS 7671:2018 - Requirements for Electrical Installations

1. External condition of intake equipment (visual inspection only) (If inadequacies are identified with the intake equipment, it is recommended the person ordering the report informs the appropriate authority)	4. Consumer unit(s) / Distribution board(s)	5. Distribution / Final circuits
1.1 Service cable: (.....) ✓	4.1 Adequacy of working space / accessibility to consumer unit / distribution board: (.....) ✓	5.1 Identification of conductors: (.....) ✓
1.2 Service head: (.....) ✓	4.2 Security of fixing: (.....) ✓	5.2 Cables correctly supported throughout: (.....) ✓
1.3 Earthing arrangement: (.....) ✓	4.3 Condition of enclosure(s) in terms of IP rating: (.....) ✓	5.3 Condition of insulation of live parts: (.....) ✓
1.4 Meter tails: (.....) ✓	4.4 Condition of enclosure(s) in terms of fire rating: (.....) ✓	5.4 Non-sheathed live conductors protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems): (.....) ✓
a) Cutout fuse to meter (.....) ✓	4.5 Enclosure not damaged / deteriorated so as to impair safety: (.....) ✓	5.5 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation: (.....) ✓
b) Meter to consumer unit (.....) ✓	4.6 Presence of linked main switch: (.....) ✓	5.6 Adequacy of protective devices: type and rated current for fault protection: (.....) ✓
1.5 Metering equipment: (.....) ✓	4.7 Operation of main switch(es) (functional check): (.....) ✓	5.7 Presence and adequacy of circuit protective conductors: (.....) ✓
1.6 Isolator (where present): (.....) ✓	4.8 Main switch capable of being secured in the OFF position: (.....) ✓	5.8 Co-ordination between conductors and overload protection devices: (.....) ✓
2. Presence of adequate arrangements for other sources	4.9 Operation of circuit-breakers and RCDs to prove disconnection (functional check): (.....) ✓	5.9 Wiring system(s) appropriate for the type and nature of the installation and external influences: (.....) ✓
2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply: (N/A)	4.10 Correct identification of circuits and protective devices: (.....) ✓	5.10 Cables adequately protected against mechanical damage and abrasion: (.....) ✓
2.2 Adequate arrangements where generating set operates in parallel with the public supply: (N/A)	4.11 Presence of appropriate circuit charts, warning and other notices: (.....) ✓	5.11 Provision of additional protection by 30 mA RCD (see Note): (.....) ✓
2.3 Presence of alternative / additional supply warning notices: (N/A)	a) Provision of circuit charts/schedules or equivalent forms of information (.....) ✓	a) For all socket-outlets with a rated current not exceeding 32 A (.....) ✓
3. Earthing and bonding arrangements	b) Warning notice of method of isolation where live parts not capable of being isolated by a single device (.....) ✓	b) For mobile equipment not exceeding a rating of 32 A (.....) ✓
3.1 Presence and condition of distributor's earthing arrangement: (.....) ✓	c) Periodic inspection and testing notice (.....) ✓	c) For cables concealed in walls / partitions at a depth of less than 50 mm (.....) ✓
3.2 Presence and condition of earth electrode connection, where appropriate: (N/A)	d) Presence of RCD six-monthly notice, where required (.....) ✓	
3.3 Confirmation of adequate earthing conductor size: (.....) ✓	e) Warning notice of non-standard (mixed) colours of conductors present (.....) ✓	
3.4 Accessibility and condition of earthing conductor at Main Earthing Terminal (MET): (.....) ✓	f) All other required labelling provided (.....) ✓	
3.5 Confirmation of adequate main protective bonding conductor sizes: (.....) ✓	4.12 Compatibility of protective device(s), base(s) and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating): (.....) ✓	
3.6 Accessibility and condition of main protective bonding conductor connections: (.....) ✓	4.13 Single-pole switching or protective devices in the line conductors only: (.....) ✓	
3.7 Accessibility and condition of other protective bonding connections: (.....) ✓	4.14 Protection against mechanical damage where cables enter consumer unit / distribution board: (.....) ✓	
3.8 Provision of earthing and bonding labels at all appropriate locations: (.....) ✓		

All fields must be completed. Enter either, as appropriate: ✓ if acceptable condition, N/A if not applicable, LIM if a limitation exists, or Code appropriately - CODE 'C1', 'C2', 'C3' or 'FI' (codes to be recorded in PART 6, with additional comments (where appropriate) on attached numbered sheets)



This report is not valid if the serial number has been defaced or altered

512927

DPN18

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

PART 10 : SCHEDULE OF ITEMS INSPECTED

5.12	For cables concealed in walls / partitions containing metal parts regardless of depth	(<input checked="" type="checkbox"/>)
e)	For all AC final circuits supplying luminaires	(<input checked="" type="checkbox"/>)
Note: Older installations designed prior to BS 7671: 2008 may not have been provided with RCDs for additional protection.		
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects:	(<input checked="" type="checkbox"/>)
5.14	Band II cables segregated / separated from Band I cables:	(<input checked="" type="checkbox"/>)
5.15	Cables segregated / separated from communications cabling:	(<input checked="" type="checkbox"/>)
5.16	Cables segregated / separated from non-electrical services:	(<input checked="" type="checkbox"/>)
5.16	Termination of cables at enclosures (extent of sampling indicated in PART 7 of the report):	(<input checked="" type="checkbox"/>)
a)	Connections soundly made and under no undue strain	(<input checked="" type="checkbox"/>)
b)	No basic insulation of a conductor visible outside enclosure	(<input checked="" type="checkbox"/>)
c)	Connection of live conductors adequately enclosed	(<input checked="" type="checkbox"/>)
d)	Adequately connected at point of entry to enclosure	(<input checked="" type="checkbox"/>)
5.17	Condition of accessories including socket-outlets, switches and joint boxes is satisfactory:	(<input checked="" type="checkbox"/>)
6.1	Isolation and switching (isolation, switching off for mechanical maintenance and functional switching)	(<input checked="" type="checkbox"/>)
In general:		
a)	Presence and condition of appropriate devices	(<input checked="" type="checkbox"/>)
b)	Correct operation verified	(<input checked="" type="checkbox"/>)
6.2	For isolation and switching for mechanical maintenance only:	(<input checked="" type="checkbox"/>)
a)	Capable of being secured in the OFF position, where appropriate	(<input checked="" type="checkbox"/>)
b)	Acceptable location (local / remote)	(<input checked="" type="checkbox"/>)
c)	Clearly identified by position and / or durable marking(s)	(<input checked="" type="checkbox"/>)
6.3	For isolation only:	(<input checked="" type="checkbox"/>)
a)	Warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	(<input checked="" type="checkbox"/>)
7.1	Condition of equipment in terms of IP rating:	(<input checked="" type="checkbox"/>)
7.2	Equipment does not constitute a fire hazard:	(<input checked="" type="checkbox"/>)
7.3	Enclosure not damaged / deteriorated so as to impair safety:	(<input checked="" type="checkbox"/>)
7.4	Suitability for the environment and external influences:	(<input checked="" type="checkbox"/>)
7.5	Security of fixing:	(<input checked="" type="checkbox"/>)
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire:	(<input checked="" type="checkbox"/>)
7.7	Recessed luminaires (downlighters):	(<input checked="" type="checkbox"/>)
a)	Correct type of lamps fitted	(<input checked="" type="checkbox"/>)
b)	Installed to minimise build-up of heat	(<input checked="" type="checkbox"/>)
c)	No signs of overheating to surrounding building fabric	(<input checked="" type="checkbox"/>)
d)	No signs of overheating to conductors / terminations	(<input checked="" type="checkbox"/>)
8.1	Additional protection by RCD not exceeding 30 mA:	(<input checked="" type="checkbox"/>)
a)	For low voltage circuits serving the location	(<input checked="" type="checkbox"/>)
b)	For low voltage circuits passing through Zone 1 and Zone 2 not serving the location	(<input checked="" type="checkbox"/>)
8.2	Where used as a protective measure, requirements for SELV or PELV are met:	(<input checked="" type="checkbox"/>)
8.3	Shaver sockets comply with BS EN 61559-2-5 (formerly BS 3535):	(<input checked="" type="checkbox"/>)
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2018:	(<input checked="" type="checkbox"/>)
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from Zone 1:	(<input checked="" type="checkbox"/>)
8.6	Suitability of equipment for external influences for installed location in terms of IP rating:	(<input checked="" type="checkbox"/>)
8.7	Suitability of equipment for installation in a particular zone:	(<input checked="" type="checkbox"/>)
9.1	Other Part 7 special installations or locations	(<input checked="" type="checkbox"/>)
List of all other special installations or locations, if any, present		
BATHROOMS		

7.1	Condition of equipment in terms of IP rating:	(<input checked="" type="checkbox"/>)
7.2	Equipment does not constitute a fire hazard:	(<input checked="" type="checkbox"/>)
7.3	Enclosure not damaged / deteriorated so as to impair safety:	(<input checked="" type="checkbox"/>)
7.4	Suitability for the environment and external influences:	(<input checked="" type="checkbox"/>)
7.5	Security of fixing:	(<input checked="" type="checkbox"/>)
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire:	(<input checked="" type="checkbox"/>)
7.7	Recessed luminaires (downlighters):	(<input checked="" type="checkbox"/>)
a)	Correct type of lamps fitted	(<input checked="" type="checkbox"/>)
b)	Installed to minimise build-up of heat	(<input checked="" type="checkbox"/>)
c)	No signs of overheating to surrounding building fabric	(<input checked="" type="checkbox"/>)
d)	No signs of overheating to conductors / terminations	(<input checked="" type="checkbox"/>)
8.1	Additional protection by RCD not exceeding 30 mA:	(<input checked="" type="checkbox"/>)
a)	For low voltage circuits serving the location	(<input checked="" type="checkbox"/>)
b)	For low voltage circuits passing through Zone 1 and Zone 2 not serving the location	(<input checked="" type="checkbox"/>)
8.2	Where used as a protective measure, requirements for SELV or PELV are met:	(<input checked="" type="checkbox"/>)
8.3	Shaver sockets comply with BS EN 61559-2-5 (formerly BS 3535):	(<input checked="" type="checkbox"/>)
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2018:	(<input checked="" type="checkbox"/>)
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from Zone 1:	(<input checked="" type="checkbox"/>)
8.6	Suitability of equipment for external influences for installed location in terms of IP rating:	(<input checked="" type="checkbox"/>)
8.7	Suitability of equipment for installation in a particular zone:	(<input checked="" type="checkbox"/>)
9.1	Other Part 7 special installations or locations	(<input checked="" type="checkbox"/>)
List of all other special installations or locations, if any, present		
BATHROOMS		

Indicate if the relevant requirements of Part 7 are satisfied and append results of inspection on a separate numbered page.

SCHEDULE OF ITEMS INSPECTED BY

Name (capitalist): Tom Weedon

Signature:

Date: 3/03/2018

PART 11 : SCHEDULES AND ADDITIONAL PAGES

Schedule of Inspections	Schedule of Circuit Details and Test Results for the installation	Additional pages, including data sheets for additional sources	Special installations or locations (indicated in item 9. above)	Continuation sheets
Page No(s):	Page No(s):	Page No(s):	Page No(s):	Page No(s):
4 & 5	6			

The pages identified are an essential part of this report (see Regulation 553.2).

All fields must be completed. Enter either, as appropriate: ✓ if Acceptable condition; N/A if Not applicable; LIM if a Limitation exists; or Code appropriately – CODE ‘C1’, ‘C2’, ‘C3’ or ‘FI’ (codes to be recorded in PART 6, with additional comments (where appropriate) on attached numbered sheets)



0-11

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

This report is not valid if the serial number has been defaced or altered

512927

DPN18

PART 12: SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing

All Equipment

CODES for Type of wiring (A) Thermoplastic insulated / stranded cables (B) Thermoplastic cables in flexible conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic conduit (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral insulated cables (I) other - state

Circuit number	Circuit description <small>* Where this consumer unit is remote from the origin of the installation, record details of the circuit supplying this consumer unit on the first line</small>	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa		Max. disconnection time (BS 7671) (s)	Protective device			RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device** (Ω)	Circuit impedances (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons				
					Live (mm ²)	CPC (mm ²)		BS (EN)	Type	Rating (A)			Short-circuit capacity (kA)	r ₁ (Live)	r _n (Neutral)	r ₂ (CPC)	R ₁ +R ₂	R _s				Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)	RCD (✓)	AFPD (✓)
1	OVEN LEFT BURNER	A	C	1	6	2.5	4	60898	B	32	6	30	1.08	N/A	N/A	N/A	0.32	N/A	205	205	250	✓	0.43	14.5	✓	N/A
2	OVEN RIGHT BURNER	A	C	1	6	2.5	4	60898	B	32	6	30	1.08	N/A	N/A	N/A	0.27	N/A	205	205	250	✓	0.40	14.5	✓	N/A
3	KITCHEN LINN	A	C	1	6	2.5	4	60898	B	32	6	30	1.08	0.48	0.49	0.26	0.54	N/A	205	205	250	✓	0.65	14.5	✓	N/A
4	GROUND FLOOR FRONT BATH	A	C	5	2.5	1.5	4	60898	B	16	6	30	2.28	N/A	N/A	N/A	0.59	N/A	205	205	250	✓	0.70	14.5	✓	N/A
5	BATH	A	C	5	2.5	1.5	4	60898	B	16	6	30	2.28	N/A	N/A	N/A	0.59	N/A	205	205	250	✓	0.70	14.5	✓	N/A
6	BATH	A	C	5	2.5	1.5	4	60898	B	16	6	30	2.28	N/A	N/A	N/A	0.59	N/A	205	205	250	✓	0.70	14.5	✓	N/A
7	1 st FLOOR SKIS	A	C	20	1.5	1.5	4	60898	B	32	6	30	1.08	0.46	0.41	0.50	0.56	N/A	205	205	250	✓	0.84	14.5	✓	N/A
8	2 nd FLOOR SKIS	A	C	24	2.5	1.5	4	60898	B	32	6	30	1.08	0.52	0.58	0.35	0.72	N/A	205	205	250	✓	1.68	14.5	✓	N/A
9	SHOWER GROUND	A	C	1	10	4	4	60898	B	40	6	30	0.87	N/A	N/A	N/A	0.33	N/A	205	205	250	✓	0.44	14.5	✓	N/A
10	SHOWER 2 nd FLOOR	A	C	1	10	4	4	60898	B	40	6	30	0.87	N/A	N/A	N/A	0.22	N/A	205	205	250	✓	0.33	14.5	✓	N/A
11	TU BOOSTER PUMP	A	C	2	2.5	1.5	4	60898	B	16	6	30	2.28	N/A	N/A	N/A	0.08	N/A	205	205	250	✓	0.16	14.5	✓	N/A
12	FIRE ALARM	A	C	1	1.5	1.5	4	60898	B	6	6	30	5.82	N/A	N/A	N/A	0.13	N/A	205	205	250	✓	0.24	14.5	✓	N/A
13	1 st FLOOR LVS	A	C	23	1	1	4	60898	B	6	6	30	5.82	N/A	N/A	N/A	1.09	N/A	205	205	250	✓	1.20	14.5	✓	N/A
14	1 st FLOOR LVS	A	C	17	1	1	4	60898	B	6	6	30	5.82	N/A	N/A	N/A	0.76	N/A	205	205	250	✓	0.89	14.5	✓	N/A
15	ALARM + GROUNDING	A	C	3	1	1	4	60898	B	6	6	30	5.82	N/A	N/A	N/A	0.45	N/A	205	205	250	✓	0.56	14.5	✓	N/A

Location of consumer unit: Hall Above front door Designation: 1 Prospective fault current at consumer unit (where applicable): 2.06 kA

TESTED BY: Name (capital): Tom Mann Position: Q.S Signature: [Signature] Date: 2.06

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: 102097503 Continuity: 102097503 Insulation resistance: 102097503 Earth fault loop impedance: 102097503 Earth electrode resistance: N/A RCD: 102097503

This report is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the NICEIC & ELECSA brands. Warwick House, Houghton Hall Park, Houghton Regis, Dunstable, LU5 5ZX. © Copyright Certsure LLP (February 2019). ** Where figure is not taken from BS 7671, state source. ()