

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

REGISTERED BUSINESS DETAILS

Reg No: **575277**
 Company: **Samie Insulation & Services**
 Address: **8 MURFORD AVE**
HULL RD
YO13 4A8
 Postcode: **YO13 4A8**
 Tel: **07814 250397**

INSPECTION/INSTALLATION ADDRESS

Name & Title:
 Address: **46A WAUGH CATE**
 Postcode: **YO1 9TS**, Tel:

LANDLORD (OR AGENT) NAME & ADDRESS (if applicable)

Name & Title: **BARBARA STANSON**
 Address: **103 TITE VILLAGE**
STOXTON ON THE FIELDS
 Postcode: **YO32 9UP** Tel: **01904 400216**
 Number of appliances tested: **026**

APPLIANCE DETAILS

Location	Make and Model	Type	Flue Type Or/FS/FL	Operating pressure in mbar or heat input kW/h or Btu/h	Safety device(s) correct Yes/No/NA	Spillage test Pass/Fail/NA	Smoke pellet test Pass/Fail/NA	Initial combustion analyser reading	Final combustion analyser reading	Satisfactory termination Yes/No/NA	Flue visual condition Pass/Fail/NA	Adequate ventilation Yes/No	Landlord's appliance inspected Yes/No	Appliance Visual Check Yes/No	Appliance serviced Yes/No	Appliance Safe to Use Yes/No
1	BATHROOM	Ideal Perfect Combi 24	COMBI RS	21MB YES	✓	✓	✓	CO2 9.0	9.1	Yes	Pass	Yes	Yes	Yes	Yes	Yes
2																
3																
4																
5																

For appliances not owned by the landlord the recorded 'Appliance Safe to Use' response is based on a visual check for obvious defects only

Gas Installation Pipework:

Satisfactory Visual Inspection: Yes No
 Emergency Control Accessible: Yes No
 Satisfactory Gas Tightness Test: Yes No
 Equipotential Bonding Satisfactory: Yes No

GIVE DETAILS OF ANY FAULTS

RECTIFICATION WORK CARRIED OUT

1	2	3	4	5	WARNING NOTICE ISSUED Yes/No/NA	WARNING TAG or STICKER FIXED Yes/No/NA

Audible CO Alarms:

Approved CO Alarms Fitted: Yes No N/A
 Are CO Alarms in Date: Yes No N/A
 Testing of CO Alarms Satisfactory: Yes No N/A
 Smoke Alarms Fitted: Yes No N/A

OTHER COMMENTS OR OBSERVATIONS

Blank area for other comments or observations.

NEXT GAS SAFETY CHECK DUE BEFORE:
18/01/23

ISSUED BY (GAS ENGINEER)

Print Name: **Samie Thackeray** Signed:
 Licence No: **575277** Issue Date: **18/01/22**

RECEIVED BY

Received By: **P. Blenkinsop** (Delete as applicable)
 Tenant/Agent/Landlord/Home Owner at time of visit
 Signed: **P. Blenkinsop** Print Name: **PACHA BLENKINSOP**