



CD/11 oil firing servicing & commissioning report

PLEASE COMPLETE ALL THE UNSHADED AREAS.

Customer (site) address LODGE FARM 1105 GRINSTEAD HULL ROAD YOVL	Company details ANDERSON HTC WELBURN YOVL
OFTEC Company Reg No. C104321	Technician name M. ANDERSON
	Technician's Reg No. C104321

Pre-commissioning checks / Legislation (Tick as appropriate) YES NO

1 If completing commissioning works, is there a completed CD/10 (or equivalent) for the installation works? **NA**

2 If the installation has been completed by a Non-Competent Person, is there a building control notice?

If YES to question 2, insert Building Control Ref. No. **NA**

Appliance make **TRIANO** Model **EVROSTAN** Serial No. **2279 0197 0018**

Burner make **RIEDEL** Model **MULTI** Type **PJ / Vap(S) / Vap(P) / Wallflame**

Tank Type Metal **Plastic** Bunded Flue Type **CF** BF / LLD Fuel type **C** / D / Biofuel (e.g. B10)

Call type (Tick as appropriate) Service Commission Breakdown Manufacturer's Warranty Return Visit

Oil firing service and commissioning schedule	Tick if passed	Parts fitted/Observations
1 Oil storage	/	
2 Oil supply system	/	NOT TO CURRENT STANDARDS
3 Air supply	/	
4 Chimney/flue	/	
5 Electrical safety	/	
6 Heat exchanger	/	SIGNS OF DETRIORATION & LEAKAGE
7 Combustion chamber	/	
8 Pressure jet burner	/	
9 Vaporising and wallflame burner	NA	
10 Wallflame burner (additional)	NA	
11 Appliance safety controls	/	
Heating system service		
12 Controls check	/	
13 System check - Hot water type	/	
14 System check - Warm air type	NA	

Important comments The comments may include advice on remedial work necessary to enable the installation to comply with the requirements of the Building Regulations, Control of Pollution and British Standards.

THE BOILER IS 25 YEARS OLD AND IS LEAKING AT THE BASE

Test results It is important to keep a record of the combustion analysis results - if they have been carried out electronically a copy of the printout should be attached to all copies of the service schedule and report. Print out attached? YES NO

Pump pressure 9 psi/bar	Efficiency Nett 88 %	Gross 84.1 %
Pump vacuum NA psi/bar	Smoke No. 0.1	CO 12 ppm
Draught NA inWG / mmWG	Nozzle (size) 1-36	(angle) 60° (pattern) ES
CO ₂ 11.4 %	Flow Rate (oil) Low cc/min.	High cc/min
Flue gas temp. 162 °C	Flow rate (DHW) Cold l/min.	Hot l/min.

I acknowledge receipt of this service and commissioning report

Recipient's name (print) **M. ANDERSON** Recipient's status (e.g. homeowner) **ENGINEER**

Recipient's signature Date **05/09/2007**